



Base wrap to extend 1" Min. (25 mm) up vertical surface of pipe and 2" Min. (51 mm) onto field membrane, with a solid hot air weld to the deck membrane.

Upper wrap to extend 1½" (38 mm) onto base wrap and 8" Min. (203 mm) up pipe and sealed into a bead of GenFlex Water Stop with a stainless steel compression band.

Refer to Detail T-7.02 for pipe wrap requirements and Detail T-7.01 for membrane securement requirements. Hood must be secured and sealed to hot pipe and fabricated so as to shed water and protect opening in roof system.



EZ TPO Systems

Hot Pipe Flashing

ACCEPTABLE SYSTEMS:
All

MAXIMUM WARRANTY: 20 Years

ISSUE / REVISION
DATE:
10-27-2015

DETAIL NO.
EZ-7.03

NOT TO SCALE