



1. When cured flashing is used on wall or curb flashing, vertical seams must be stripped-in at the base of angle change with a 6" (152 mm) strip of FlexFlash E, or 7" (178 mm) Peel & Stick. See Detail E-3.01.
2. All parapet walls and roof curbs must be suitable for flashing, e.g. clean, tight, smooth, no cracks, etc.
3. Compression fit details that incorporate GenFlex Water Stop must have all existing flashing removed to the bare substrate, e.g. masonry block.
4. Any approved pre-drilled fastener for curb and parapet terminations must have a minimum 125 lb (556 N) pullout. See approved fastener list.
5. For horizontal application of termination bar, all edges of bar and pre-drilled holes must be caulked with GenFlex Termination Caulk.



Parapet Wall with Termination Bar

EPDM Systems

ACCEPTABLE SYSTEMS:
All Roof Systems

MAXIMUM WARRANTY: **20 Years**

ISSUE / REVISION
DATE:
6-22-2015

NOT TO SCALE

DETAIL NO.

E-1.07